

**LABORATORY REPORT**

Plum Borough School District  
900 Elicker Rd  
Plum, PA 15239

RJ Lee Group Job No.: PA09052017P027  
Samples Received: May 8, 2017  
Report Date: May 16, 2017  
Client Project: N/A  
Purchase Order No.: N/A  
Prep/Analysis: EPA 200.8

Attn: Tom Holleran  
Phone: 412-798-6366

Email: holleranb@pbsd.k12.pa.us

Client Sample ID	RJ Lee Group ID	Sampling Date	Preparation/ Analysis	Analyte	Matrix	Sample Concentration Total µg/L (PPB)	Minimum Reporting Limit µg/L (PPB)	Analysis Date	Q
1-OBLOCK	PA09052017P027-001	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
2-OBLOCK	PA09052017P027-002	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
3-OBLOCK	PA09052017P027-003	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
4-OBLOCK	PA09052017P027-004	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
5-HOLIDAY PK	PA09052017P027-005	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
6-HOLIDAY PK	PA09052017P027-006	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
7-HP	PA09052017P027-007	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
8-HP	PA09052017P027-008	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
9-PHS	PA09052017P027-009	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
10-PHS	PA09052017P027-010	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
11-PHS	PA09052017P027-011	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
12-PHS	PA09052017P027-012	05/04/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
15-CENTER	PA09052017P027-013	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
16-CENTER	PA09052017P027-014	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
17-CENTER	PA09052017P027-015	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
18-CENTER	PA09052017P027-016	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
19-PIVIK	PA09052017P027-017	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
20-PIVIK	PA09052017P027-018	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
21-PIVIK	PA09052017P027-019	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
22-PIVIK	PA09052017P027-020	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
23-RP	PA09052017P027-021	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
24-RP	PA09052017P027-022	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC
25-RP	PA09052017P027-023	05/05/2017	EPA 200.8	Lead	Drinking Water	1.04	1.00	05/15/2017	PNC
26-RP	PA09052017P027-024	05/05/2017	EPA 200.8	Lead	Drinking Water	< 1.00	1.00	05/15/2017	PNC

Analyst Comments:

Report Qualifiers (Q):

P : PA-DEP Accredited (PA DEP Lab ID 02-00396, NELAP)

N : NY ELAP Accredited (NY ELAP Lab Code 10884)

E = Value above highest calibration standard

J = Value below lowest calibration standard but above MDL (Method Detection Limit)

B = Analyte detected in the associated Method Blank

S = Spike Recovery outside accepted limits

**LABORATORY REPORT**

Plum Borough School District  
900 Elicker Rd  
Plum, PA 15239

RJ Lee Group Job No.: PA09052017P027  
Samples Received: May 8, 2017  
Report Date: May 16, 2017  
Client Project: N/A  
Purchase Order No.: N/A  
Prep/Analysis: EPA 200.8

Attn: Tom Holleran  
Phone: 412-798-6366

Email: holleranb@pbsd.k12.pa.us

Client Sample ID	RJ Lee Group ID	Sampling Date	Preparation/ Analysis	Analyte	Matrix	Sample Concentration Total µg/L (PPB)	Minimum Reporting Limit µg/L (PPB)	Analysis Date	Q
------------------	-----------------	---------------	-----------------------	---------	--------	---------------------------------------	------------------------------------	---------------	---

C : CA ELAP Accredited (CA ELAP Certificate 1970)  
— : Test (analyte-matrix-preparation-analysis) is performed under R.J.L.G's General Quality System requirements and is not part to any of the above scopes of accreditations

L = LCS (Laboratory Control Standard)/SRM (Standard Reference Material) recovery outside accepted recovery limits  
H = Holding times for preparation or analysis exceeded

R = RPD (relative percent difference) outside accepted limits  
D = RL (reporting limit verification) outside accepted limits  
NP = Not Provided

*These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, RJ Lee Group will store the samples for a period of thirty (30) days before discarding. A shipping and handling fee will be assessed for the return of any samples.*

*This laboratory operates in accord with ISO 17025:2005 guidelines, and holds a limited scope of accreditations under different accrediting agencies; refer to <http://www.rjlg.com/about-us/accreditations/> for more information and current status. This report may not be used to claim product endorsement by any laboratory accrediting agency. The results contained in this report relate only to the items tested or to the sample(s) as received by the laboratory. Any reproduction of this document must be in full for the report to be valid.*

*Unless otherwise noted (either in the comments section of the report and/or with the appropriate qualifiers under the report qualifiers (Q) column) the following apply: (a) Samples were received in good condition, (b) All QC samples are within acceptable established limits, (c) All samples designated as NELAP meet the requirements of the NELAC standard; if not applicable qualifiers will be used to designate the non-compliance and (d) Results have not been blank corrected. Quality Control data is available upon request.*

